

| <b>REPORT DOCUMENTATION PAGE</b>  |                    |                                       |                                   | Form Approved<br>OMB No. 0704-0188                              |  |
|---|--------------------|---------------------------------------|-----------------------------------|---|--|
| Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing this collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports (0704-0188), 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number. <b>PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.</b>   |                    |                                       |                                   |   |  |
| <b>1. REPORT DATE (DD-MM-YYYY)</b><br>23-03-2007  |                    | <b>2. REPORT TYPE</b><br>Final Report |                                   | <b>3. DATES COVERED (From - To)</b><br>01-10-2004 to 30-11-2006 |  |
| <b>4. TITLE AND SUBTITLE</b><br>Development of a Flow-Through SQUID System<br>for Non-Destructive Evaluation of MRI Wire  |                    |                                       |                                   | <b>5a. CONTRACT NUMBER</b><br>FA95500510028                     |  |
|   |                    |                                       |                                   | <b>5b. GRANT NUMBER</b>   |  |
|   |                    |                                       |                                   | <b>5c. PROGRAM ELEMENT NUMBER</b>                               |  |
|   |                    |                                       |                                   | <b>5d. PROJECT NUMBER</b>                                       |  |
| <b>6. AUTHOR(S)</b><br>Frederick C. Wellstood   |                    |                                       |                                   | <b>5e. TASK NUMBER</b>  |  |
|   |                    |                                       |                                   | <b>5f. WORK UNIT NUMBER</b>                                     |  |
|   |                    |                                       |                                   |   |  |
| <b>7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES)</b><br>Department of Physics<br>University of Maryland<br>College Park, Maryland,<br>20742-4111   |                    |                                       |                                   | <b>8. PERFORMING ORGANIZATION REPORT NUMBER</b>                 |  |
| <b>9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES)</b><br>AFOSR/PKC (ATTN: Wendy Veon)<br>875 North Randolph Street<br>Suite 325, Room 3112<br>Arlington, VA 22203-1768.<br><i>Dr Harold</i>  |                    |                                       |                                   | <b>10. SPONSOR/MONITOR'S ACRONYM(S)</b>                         |  |
|   |                    |                                       |                                   | <b>11. SPONSOR/MONITOR'S REPORT NUMBER(S)</b>                   |  |
|   |                    |                                       |                                   |   |  |
| <b>12. DISTRIBUTION / AVAILABILITY STATEMENT</b><br><div style="display: flex; justify-content: space-between;"> <div style="text-align: center;"> <b>DISTRIBUTION STATEMENT A</b><br/>           Approved for Public Release<br/>           Distribution Unlimited         </div> <div style="text-align: right;">AFRL-SR-AR-TR-07-0123</div> </div>   |                    |                                       |                                   |   |  |
| <b>13. SUPPLEMENTARY NOTES</b>  |                    |                                       |                                   |   |  |
| <b>14. ABSTRACT:</b> This project developed techniques to detect small defects in NbTi magnet wire at room-temperature using a flow-through high-transition temperature ( $T_c$ ) superconducting quantum interference device (SQUID) system. The ability to detect small defects in km-long sections of NbTi magnet wire could improve the production yield of high-field magnets for power and medical applications. Such magnets are wound from continuous sections of wire up to 1 km long, and a single small defect in the wire can limit the field the magnet produces, making it unsuitable. It is highly desirable to be able to locate defects in wire using non-destructive evaluation (NDE) of the wire before the magnet is wound. Ideally, the NDE system must be able to detect small buried defects due to yields (wire stretched beyond elastic limit) and occlusions (non-conducting impurity grain introduced into the wire). Such defects have proven to be difficult to find using visual inspection or conventional eddy current detection, and better techniques are needed. |                    |                                       |                                   |   |  |
| <b>15. SUBJECT TERMS</b><br>NDE, Superconducting, SQUID, Magnet   |                    |                                       |                                   |   |  |
| <b>16. SECURITY CLASSIFICATION OF:</b>  |                    |                                       | <b>17. LIMITATION OF ABSTRACT</b> | <b>18. NUMBER OF PAGES</b><br><br>3                             | <b>19a. NAME OF RESPONSIBLE PERSON</b>                           |
| <b>a. REPORT</b>  | <b>b. ABSTRACT</b> | <b>c. THIS PAGE</b>                   |                                   |   | <b>19b. TELEPHONE NUMBER (include area code)</b><br>301-405-7649 |

**Final Performance Report for  
Development of a Flow-Through SQUID System  
for  
Non-Destructive Evaluation of MRI Wire**

**AFOSR Award Number FA95500510028**

**University of Maryland FRS # 01-5-28399**

**From:** Fred Wellstood  
Center for Superconductivity Research  
Department of Physics  
University of Maryland  
College Park, Maryland 20742-4111  
Phone 301-405-7649, well@squid.umd.edu

**To:** Air Force Office of Scientific Research  
ATTN: Wendy M Veon -PKC  
875 North Randolph Street  
Suite 325 , Room 3112  
Arlington , VA 22203-1768

**Date:** March 23, 2007

**Cc:** Cleopatra White, Center for Superconductivity Research;  
Hasti Mehta, Compliance Coordinator,  
Office of Research Administration and Advancement, UMD

**20070417191**

The objective of this project was to develop techniques to detect small defects in km-long sections of NbTi magnet wire at room-temperature using a flow-through high-transition temperature ( $T_c$ ) superconducting quantum interference device (SQUID) system. The ability to detect small defects in km-long sections of NbTi magnet wire could improve the production yield of high-field magnets for Medical Resonance Imaging (MRI) and power applications. Such magnets are wound from continuous sections of wire up to 1 km long, and a single small defect in the wire can limit the field the magnet produces, making it unsuitable. Ideally, the NDE system must be able to detect small buried defects due to yields (wire stretched beyond elastic limit) and occlusions (non-conducting impurity grain introduced into the wire). Such defects have proven to be difficult to find using visual inspection or conventional eddy current detection, and better technique are needed.

During the two years of this project, the main tasks we accomplished were:

- (1) Built a stepper motor controlled wire feed system and tested it on a cryo-cooled flow-through high- $T_c$  SQUID system;
- (2) Used the system to measure ac magnetic signals from intentional defects (small through holes) in 6 ft long 2 mm diameter brass rod driven at up to 20 cm/s;
- (3) Developed a simple automatic detection scheme using high pass filter and threshold detection to reliably detect through holes down to 300  $\mu$ m diameter;
- (4) Rebuilt SQUID tip and electronics for higher bandwidth (about 20 kHz) and tested the complete system;
- (5) Developed a simple model of the defect signal, compared observed signals to the model, and developed estimates for minimum defect size observable with a given level of injection current;
- (5) Considered two designs for alternative detection schemes. The aim of the first scheme was to improve the detection of smaller holes by using a coaxial return current path that would produce a field that would cancel the background field from the average current through the wire under test. The aim of the second techniques was to remove the need for making connections to the wire by using a pair of anti-Helmholtz coils to produce a large field gradient that the wire would then be swept through.